

Tele: 2666598

Garrison Engineer (NW)
Kataribagh, Naval Base PO
Kochi- 682004

2105/KV/ 131 /E2

03 Mar 2022

✓
Kendriya Vidyalaya No.2
Naval Base
Kochi-68200a

ISSUE OF STRUCTURAL STABILITY CERTIFICATE - REG

1. Ref your letter No. 47/KV2 CHN/2021-22/148 dt 21 Dec 2021.
2. Kendriya Vidyalaya No. 2 school building at Naval Base Kochi has been inspected by GE (NW) team. The following points have been observed.
 - (a) Horizontal cracks on lower portion of beam in corridor.
 - (b) Diagonal cracks from window/ventilator opening at certain locations in primary section building.
 - (c) Plaster cracks at few locations.
 - (d) Dampness and minor leakage at certain locations.
3. It is certified that the building seems structurally safe by visual inspection through naked eyes.



(SK Choudhary, IDSE)
EE
Garrison Engineer (NW)

Copy to :-

AGE B/R III - For info wrt your subdivision letter No 258/KV/09/E2 dt 01 Mar 2022.